


Polyester Powder Coat Finish
COLOUR:-

240 Volts 1ph Supply Drive Motor.

Client to provide mains supply terminated with an IEC 60309-2 1 Phase, 2 Pin & earth socket positioned within 1 metre of motor position.

Site Wiring by:- Advanced Doors Ltd

Complete With Controlled Descent And Activation by:- Auto Reset Solenoid System (Client to provide a 24vDC (3 amp) supply. Connection to Fire Alarm by:- Others



PLEASE DO NOT SCALE

ADVANCED DOORS LTD.



Park Mill Way
Clayton West Ind. Est.
Clayton West
Huddersfield
West Yorkshire
HD8 9XJ

Tele (01484) 861112
Fax (01484) 861056
email: info@advanceddoors.co.uk
internet: www.advanceddoors.co.uk

CLIENT:-

SITE:-

DETAILS OF No. "FIREBLADE" 4 HOUR FIRE RESISTING ROLLERSHUTTER DOOR(S) WITH CONTROLLED DESCENT.

NOTES:-

REVISIONS

DRAWING NUMBER

REV

DATE

DRAWN

CHECKED